


# ISO 50001 Energy Management System Case Study

2020

Egypt

## Misir Fertilizers Production Company (MOPCO)

*MOPCO succeeded to transition to the new version of the International Standard for Energy Management System ISO 50001:2018.*



### Organization Profile & Business Case

MOPCO, one of the petroleum sector companies, founded in July 26, 1998 according to rules and provisions of the law of Investment guaranties and incentives number 8 issued in 1997 inside the free zone in Damietta on a space that is 400.000 meters square allocated for MOPCO project and the future expansions. This project produces Urea as a main product and liquid. MOPCO Train one that began operating in 2008 and other two Train that began operating in 2015 and 2016 respectively.

Each plant producing approximately 1200 metric tons per day (mtpd) of Ammonia (UHDE technology), 1925 mtpd urea Granulation (Stamicarbon technology). MOPCO has established an Energy Management System (EnMS) for all Ammonia and urea production process as part of the continuous management support for sustainable improvement for energy and environmental performance all over the time. MOPCO has been proceeded in this project in order to better understand

the key risks and opportunities associated with the use of energy in our operations.

*“Successful implementation of EnMS depends on commitment from all levels and functions of the organization, and especially from top management.”*

—Hisham Nour El-Dein, CEO

### Case Study Snapshot



Industry	Chemicals
Product/Service	Urea and Ammonia
Location	Egypt – Damietta free Zone
Energy management system	ISO 50001:2018
Energy performance improvement period, in years	4 years
Energy Performance Improvement (%) over improvement period	11.7 % ( 2.9% per year)
Total energy cost savings over improvement period	3,992,896 \$USD
Cost to implement EnMS	1.5 Million \$USD
Total Energy Savings over improvement period	1,533,272 Gj
Total CO <sub>2</sub> -e emission reduction over improvement period	212,614 Tons

## Business Benefits

The implementation of the Energy Management System according to ISO 50001 has improved the energy performance from 2016 to 2019 in 11.7 % regarding the baseline defined. The total energy saving is 425,909 MWH. The saving reached during the period 2016-2019 is of about 4 Million USD.

### Indirect benefits:

- Awareness of the staff about the importance of the energy rational use.
- Participate all the organization levels to improve work efficiency.
- Improve the management of energy saving and consumption reduction.
- Form a mechanism with a variety of management means, and improve the overall effect and efficiency of energy conservation work.



### MOPCO Story for Process and Energy optimization




## Plan


Every Three years MOPCO makes plan for overall deployment of energy saving and water saving. At the beginning of each year, we review the energy balance, Scope , Boundaries and SEUs'.

MOPCO top management realized that the best approach for implementing an effective EnMS is by appointing energy management representative , establishing steering energy committee directed by chairman production and establishing executive energy committee.

### Significant Energy users for Electricity



### Significant Energy users for Fuel Gas



***“Implementing an energy management system is the easiest way to increase profit”***

— Hisham Nour El-Dein, CEO

## Do, Check, Act

The implementation of the operational controls, detailed operation procedures, and monitoring via an online system on MPA to track MOPCO 3 plant performance and specific consumption for ammonia and urea to reduce the deviation of energy consumption. Operators should keep the consumptions defined as significant within the established ranges. A daily energy report is also issued and includes;

- Energy specific consumption for Ammonia and urea plants.
- Boiler performance.
- Generator performance.
- Energy performance indicators based on UNODO methodology.

# Daily Energy Report

Site Facilities Production Company  
Technical Studies, Development  
and Energy Conservation General Management

Date14/08/2018

## Annexes According to T.S.R.C methodology

Status	N.G Energy Consumption	Steam Energy Consumption	Power Energy Consumption "Plant"	Power Energy "Grid"	Total Energy Consumption/Average	Eff. Relative %
Performance	3.325	0.288	0.263	0.014	7.519	
Actual	7.854	0.708	0.235	0.225	8.330	35.057

## Urea According to T.S.R.C methodology

Status	Refer to AnnexeA Consumption	Urea Energy Consumption	Power Energy Consumption "Plant"	Power Energy "Grid"	Total Energy Consumption/Urea Production (t/tonUrea)	Eff. Relative %
Performance	4.432	0.705	0.262	0.019	6.420	
Actual	8.715	0.713	0.148	0.004	9.591	98.218

## Annexes According to Urea methodology

Status	Total N.G. Spec. Consumption	Excess MPS Spec. Consumption	MPS to DFW Spec. Consumption	MPS to Refr. Turb. Spec. Consumption	Excess Water producing Spec.	Total Spec. Consumption	Eff. Relative %	Fluestack Loss (t/day)
Performance	7.454	-0.758	0.6949	0.0162	0.1376	7.202		5525.973
Actual	8.084	-0.280	0.838	0.008	0.448	8.781	91.001	

## Energy Performance indicators acc. to UNEFCO methodology

Status	Bol Fuel Actual Cons. KWH	Bol Fuel Expected Cons. KWH	EnPC	Bol Fuel Actual Cons. KWH	Bol Fuel Expected Cons. KWH	EnPC	Total Energy Actual Cons. KWH	Total Energy Expected Cons. KWH	EnPC
Target			<=1			<=1			<=1
Actual	253204	245119	1.0334	331361	344676	0.9592	3647945	4018119	0.9103

## Boiler KPIs

Status	Boiler Efficiency (%)	Boiler Capacity(t/ra/h)	Rate (Net) (kg/Net steam)
Performance	88.672	0.751	84.738
Actual	84.498	0.730	84.856

## Generator KPIs

Status	Generator eff. (Tons/Mwh)	Generator Specific Cons. (Mcal/Mwh)	Generator unit Efficiency (%)
Performance	3.550	2.860	30.69%
Actual	3.847	3.090	28.18%

## Notes:

- \* Specific Enthalpy of Water (KJ/kg)554.608 At 125 Bar &130 C
- \* Specific Enthalpy of Steam (KJ/kg)3300.45 At 115 Bar & 510 C
- \* LHV: is changed data, after correction, and to CHN (1587 cody Units) instead of (ISO 9979 GASCO)
- \* The expected consumption is calculated based on regression analysis for Energy production and Urea production of year 2016.

and maintenance teams to implement the whole energy system stuck with ISO 50001:2008 policies and recommendations.

We use a PESTLE Analysis and SWOT Analysis; to define the external issues affecting our energy performance and define opportunities and risks

- Establishing an energy management culture at all levels in the organization requires great contribution and support on the part of the management. A
- Progressing towards having an energy management system in the two sites of the company.

## Transparency

MOPCO was certified by the third party ISO50001 in Dec.2019 .MOPCO is the first fertilizer company independent company to pass ISO50001:2018 certification.

MOPCO's Business Strategy addresses directly one of the modernization project pillars and aligned with Egypt's Vision 2030 - Downstream Performance, where in May 2019, MOPCO has awarded an appreciated Certificate from the ministry of petroleum and mineral resources during the 2nd energy efficiency conference as a result of decreasing energy consumption by implementing no and low-cost opportunities during 2018.



## Lessons Learned

Through the Energy Management Working Group (EMWG), government officials worldwide share best practices and leverage their collective knowledge and experience to create high-impact national programs that accelerate the use of energy management systems in industry and commercial buildings. The EMWG was launched in 2010 by the Clean Energy Ministerial (CEM) and International Partnership for Energy Efficiency Cooperation (IPEEC).

For more information, please visit [www.cleanenergyministerial.org/energymanagement](http://www.cleanenergyministerial.org/energymanagement).

